



NOTE "A"

☐ CMC 916.1.2: Vertical Clearance Above Cooking Top. Household cooking appliances shall have a vertical clearance above the cooking top of not less than thirty (30) inches to combustible material or metal cabinets. A minimum clearance of twenty-four (24) inches is permitted when one of the following is installed:

- The underside of the combustible material or metal cabinet above the cooking top is protected with not less than one-fourth of inch insulating millboard covered with sheet metal not less than 0.0122 inch thick.
- A metal ventilating hood of sheet metal not less than 0.0122 inch thick is installed above the cooking top with a clearance of not less than one fourth of inch between the hood and the underside of the combustible material or metal cabinet, and the hood is at least as wide as the appliance and is centered over the appliance.
- A listed cooking appliance or microwave oven is installed over a listed cooking appliance and will conform to the terms of the upper appliance's listing and the manufacturer's instructions. [NFPA 54: 10.15.1.2]

REV.	DATE	BY:	SCALE:
1	01/2011	BK	N.T.S
2	12/2014	VP	DATE: AUG. 2006
			DRAWN BY: BK.

City of Milpitas
 Building & Safety Division
RESIDENTIAL COOK-TOP RANGE

SHEET
1
OF 1 SHEETS