



**City of Milpitas  
Building And Safety Division**

Mailing Address: 455 East Calaveras Boulevard, Milpitas,  
California 95035-5479 – Tel. 408.586.3240, Fax 408.586.3285  
[www.ci.milpitas.ca.gov](http://www.ci.milpitas.ca.gov)

Policy: BDP-BLG21

Effective Date: 7/1/2008

Revision Number

Last Revised

**COMMON PATH OF TRAVEL  
FROM SECOND FLOOR**

Approved By: Keyvan Irannejad P.E.  
Chief Building Official

Proposed By: TUCC

**CODE REFERENCES:**

2007 CBC Sections 1002, 1014.3 and 1016.1.

**ISSUES:**

- 1) How is the common path of egress travel from a second floor in existing two story buildings determined when the definition of this distance contains the phrase: *before two separate and distinct paths of egress travel to two exits are available.*
- 2) In existing two story office buildings open stairways commonly provide egress to the first floor level. Because open stairs are NOT considered an exit, it appears that the common path of travel for occupants on the second floor must extend to the first floor level (level of exit discharge) before two separate and distinct paths of egress travel to two “exits” are available. This distance can easily exceed 100 feet in many office building.

**POLICY:**

2007 CBC Section 1014.3 **Common path of egress travel** - On the second floor level of two-story buildings, once an occupant enters a circulation corridor or hallway that provides two separate directions of travel to two properly separated existing stairs, then that is the point at which the common path of travel has ended. One need not reach the ground floor level to achieve the intent of having two separate and distinct paths of egress travel if the existing stairs are properly separated.